

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 25)**

Water Level of the accumulated water (at 7:00 on February 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,855 mm (15 mm increase since 7:00 on February 24)	O.P.+ 2,485 mm (23 mm decrease since 7:00 on February 24)	—
	Water level of Turbine Building	O.P.+ 2,493 mm (7 mm increase since 7:00 on February 24)	O.P.+ 2,706 mm (25 mm decrease since 7:00 on February 24)	O.P.+ 2,519 mm (38 mm decrease since 7:00 on February 24)	O.P.+ 2,545 mm (12 mm decrease since 7:00 on February 24)
	Water level of Reactor Building	O.P.+ 4,061 mm (27 mm increase since 7:00 on February 24)	O.P.+ 2,813 mm (24 mm decrease since 7:00 on February 24)	O.P.+ 2,531 mm (42 mm decrease since 7:00 on February 24)	O.P.+ 2,562 mm (8 mm decrease since 7:00 on February 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,520 mm (Increase from initial level:5,737 mm, 54 mm increase since 7:00 on February 24) O.P.+ 2,969 mm (Increase from initial level:3,695 mm, 487 mm increase since 7:00 on February 24) O.P.+ 4,339 mm (Water level from floor:543 mm, No change since 7:00 on February 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on February 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:39 on February 23)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 24 to 15:00 on February 24)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:54 on February 25 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.