

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 27)**

Water Level of the accumulated water (at 7:00 on February 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,885 mm (17 mm increase since 7:00 on February 26)	O.P.+ 2,588 mm (86 mm increase since 7:00 on February 26)	—
	Water level of Turbine Building	O.P.+ 2,505 mm (8 mm increase since 7:00 on February 26)	O.P.+ 2,608 mm (49 mm decrease since 7:00 on February 26)	O.P.+ 2,640 mm (51 mm increase since 7:00 on February 26)	O.P.+ 2,574 mm (29 mm increase since 7:00 on February 26)
	Water level of Reactor Building	O.P.+ 4,099 mm (23 mm increase since 7:00 on February 26)	O.P.+ 2,742 mm (33 mm decrease since 7:00 on February 26)	O.P.+ 2,661 mm (65 mm increase since 7:00 on February 26)	O.P.+ 2,575 mm (17 mm increase since 7:00 on February 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,664 mm (Increase from initial level:5,881 mm, 46 mm increase since 7:00 on February 26) O.P.+ 3,068 mm (Increase from initial level:3,794 mm, 7 mm increase since 7:00 on February 26) O.P.+ 4,343 mm (Water level from floor:547 mm, 2 mm increase since 7:00 on February 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:32 on February 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:39 on February 23)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 26 to 15:00 on February 26)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:46 on February 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.