

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 1)**

Water Level of the accumulated water (at 7:00 on March 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,912 mm (14 mm increase since 7:00 on February 28)	O.P.+ 2,603 mm (4 mm increase since 7:00 on February 28)	—
	Water level of Turbine Building	O.P.+ 2,513 mm (3 mm increase since 7:00 on February 28)	O.P.+ 2,738 mm (68 mm increase since 7:00 on February 28)	O.P.+ 2,640 mm (38 mm increase since 7:00 on February 28)	O.P.+ 2,598 mm (9 mm increase since 7:00 on February 28)
	Water level of Reactor Building	O.P.+ 4,107 mm (7 mm increase since 7:00 on February 28)	O.P.+ 2,802 mm (59 mm increase since 7:00 on February 28)	O.P.+ 2,660 mm (36 mm increase since 7:00 on February 28)	O.P.+ 2,601 mm (11 mm increase since 7:00 on February 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,562 mm (Increase from initial level:5,779 mm, 143 mm decrease since 7:00 on February 28) O.P.+ 3,077 mm (Increase from initial level:3,803 mm, 4 mm increase since 7:00 on February 28) O.P.+ 4,346 mm (Water level from floor:550 mm, 3 mm increase since 7:00 on February 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (From 10:39 on February 23 to 9:55 on February 28)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:46 on February 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:25 on February 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.