

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 4)**

Water Level of the accumulated water (at 7:00 on March 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,178 mm (3 mm increase since 7:00 on March 3)	O.P.+ 2,651 mm (14 mm increase since 7:00 on March 3)	—
	Water level of Turbine Building	O.P.+ 2,554 mm (14 mm increase since 7:00 on March 3)	O.P.+ 2,767 mm (28 mm decrease since 7:00 on March 3)	O.P.+ 2,665 mm (30 mm decrease since 7:00 on March 3)	O.P.+ 2,651 mm (14 mm increase since 7:00 on March 3)
	Water level of Reactor Building	O.P.+ 4,285 mm (7 mm increase since 7:00 on March 3)	O.P.+ 2,885 mm (19 mm decrease since 7:00 on March 3)	O.P.+ 2,693 mm (27 mm decrease since 7:00 on March 3)	O.P.+ 2,648 mm (16 mm increase since 7:00 on March 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,583 mm (Increase from initial level:5,800 mm, 196 mm increase since 7:00 on March 3) O.P.+ 3,202 mm (Increase from initial level:3,928 mm, 4 mm increase since 7:00 on March 3) O.P.+ 4,356 mm (Water level from floor:560 mm, 2 mm increase since 7:00 on March 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on March 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on March 3 to 15:00 on March 3)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:57 on March 2   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:26 on March 2   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.