

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 5)**

Water Level of the accumulated water (at 7:00 on March 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,185 mm (7 mm increase since 7:00 on March 4)	O.P.+ 2,656 mm (5 mm increase since 7:00 on March 4)	—
	Water level of Turbine Building	O.P.+ 2,573 mm (19 mm increase since 7:00 on March 4)	O.P.+ 2,747 mm (20 mm decrease since 7:00 on March 4)	O.P.+ 2,659 mm (6 mm decrease since 7:00 on March 4)	O.P.+ 2,655 mm (4 mm increase since 7:00 on March 4)
	Water level of Reactor Building	O.P.+ 4,303 mm (18 mm increase since 7:00 on March 4)	O.P.+ 2,863 mm (22 mm decrease since 7:00 on March 4)	O.P.+ 2,688 mm (5 mm decrease since 7:00 on March 4)	O.P.+ 2,656 mm (8 mm increase since 7:00 on March 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,685 mm (Increase from initial level:5,902 mm, 102 mm increase since 7:00 on March 4) O.P.+ 3,213 mm (Increase from initial level:3,939 mm, 11 mm increase since 7:00 on March 4) O.P.+ 4,359 mm (Water level from floor:563 mm, 3 mm increase since 7:00 on March 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on March 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on March 4 to 15:00 on March 4)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:34 on March 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:26 on March 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.