

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 6)**

Water Level of the accumulated water (at 7:00 on March 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,187 mm (2 mm increase since 7:00 on March 5)	O.P.+ 2,623 mm (33 mm decrease since 7:00 on March 5)	—
	Water level of Turbine Building	O.P.+ 2,589 mm (16 mm increase since 7:00 on March 5)	O.P.+ 2,722 mm (25 mm decrease since 7:00 on March 5)	O.P.+ 2,636 mm (23 mm decrease since 7:00 on March 5)	O.P.+ 2,643 mm (12 mm decrease since 7:00 on March 5)
	Water level of Reactor Building	O.P.+ 4,291 mm (12 mm decrease since 7:00 on March 5)	O.P.+ 2,826 mm (37 mm decrease since 7:00 on March 5)	O.P.+ 2,662 mm (26 mm decrease since 7:00 on March 5)	O.P.+ 2,648 mm (8 mm decrease since 7:00 on March 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,728 mm (Increase from initial level:5,945 mm, 43 mm increase since 7:00 on March 5) O.P.+ 3,234 mm (Increase from initial level:3,960 mm, 21 mm increase since 7:00 on March 5) O.P.+ 4,361 mm (Water level from floor:565 mm, 2 mm increase since 7:00 on March 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on March 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:34 on March 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:26 on March 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.