

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 7)**

Water Level of the accumulated water (at 7:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,190 mm (3 mm increase since 7:00 on March 6)	O.P.+ 2,625 mm (2 mm increase since 7:00 on March 6)	—
	Water level of Turbine Building	O.P.+ 2,604 mm (15 mm increase since 7:00 on March 6)	O.P.+ 2,695 mm (27 mm decrease since 7:00 on March 6)	O.P.+ 2,614 mm (22 mm decrease since 7:00 on March 6)	O.P.+ 2,640 mm (3 mm decrease since 7:00 on March 6)
	Water level of Reactor Building	O.P.+ 4,274 mm (17 mm decrease since 7:00 on March 6)	O.P.+ 2,806 mm (20 mm decrease since 7:00 on March 6)	O.P.+ 2,637 mm (25 mm decrease since 7:00 on March 6)	O.P.+ 2,647 mm (1 mm decrease since 7:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,769 mm (Increase from initial level:5,986 mm, 41 mm increase since 7:00 on March 6) O.P.+ 3,261 mm (Increase from initial level:3,987 mm, 27 mm increase since 7:00 on March 6) O.P.+ 4,363 mm (Water level from floor:567 mm, 2 mm increase since 7:00 on March 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on March 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building Temporary Tank	Transfer Completed	(From 10:00 on March 6 to 15:00 on March 6)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:34 on March 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:26 on March 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.