

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 8)**

Water Level of the accumulated water (at 7:00 on March 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,192 mm (2 mm increase since 7:00 on March 7)	O.P.+ 2,617 mm (8 mm decrease since 7:00 on March 7)	—
	Water level of Turbine Building	O.P.+ 2,620 mm (16 mm increase since 7:00 on March 7)	O.P.+ 2,673 mm (22 mm decrease since 7:00 on March 7)	O.P.+ 2,663 mm (49 mm increase since 7:00 on March 7)	O.P.+ 2,630 mm (10 mm decrease since 7:00 on March 7)
	Water level of Reactor Building	O.P.+ 4,265 mm (9 mm decrease since 7:00 on March 7)	O.P.+ 2,787 mm (19 mm decrease since 7:00 on March 7)	O.P.+ 2,683 mm (46 mm increase since 7:00 on March 7)	O.P.+ 2,638 mm (9 mm decrease since 7:00 on March 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,661 mm (Increase from initial level:5,878 mm, 108 mm decrease since 7:00 on March 7) O.P.+ 3,293 mm (Increase from initial level:4,019 mm, 32 mm increase since 7:00 on March 7) O.P.+ 4,364 mm (Water level from floor:568 mm, 1 mm increase since 7:00 on March 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 9:58 on March 3 to 10:16 on March 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:34 on March 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:26 on March 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.