

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 9)**

Water Level of the accumulated water (at 7:00 on March 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,197 mm (5 mm increase since 7:00 on March 8)	O.P.+ 2,632 mm (15 mm increase since 7:00 on March 8)	—
	Water level of Turbine Building	O.P.+ 2,633 mm (13 mm increase since 7:00 on March 8)	O.P.+ 2,655 mm (18 mm decrease since 7:00 on March 8)	※Data not obtained due to failure in water gauge	O.P.+ 2,641 mm (11 mm increase since 7:00 on March 8)
	Water level of Reactor Building	O.P.+ 4,268 mm (3 mm increase since 7:00 on March 8)	O.P.+ 2,770 mm (17 mm decrease since 7:00 on March 8)	O.P.+ 2,717 mm (34 mm increase since 7:00 on March 8)	O.P.+ 2,645 mm (7 mm increase since 7:00 on March 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,490 mm (Increase from initial level:5,707 mm, 171 mm decrease since 7:00 on March 8) O.P.+ 3,331 mm (Increase from initial level:4,057 mm, 38 mm increase since 7:00 on March 8) O.P.+ 4,367 mm (Water level from floor:571 mm, 3 mm increase since 7:00 on March 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:34 on March 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:26 on March 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.