

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 11)**

Water Level of the accumulated water (at 7:00 on March 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,458 mm (32 mm increase since 7:00 on March 10)	O.P.+ 2,731 mm (54 mm increase since 7:00 on March 10)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (54 mm increase since 7:00 on March 10)	O.P.+ 2,656 mm (7 mm increase since 7:00 on March 10)	※ No data has been obtained due to the flaw in water level indicator.	O.P.+ 2,704 mm (34 mm increase since 7:00 on March 10)
	Water level of Reactor Building	O.P.+ 4,616 mm (45 mm increase since 7:00 on March 10)	O.P.+ 2,790 mm (4 mm decrease since 7:00 on March 10)	O.P.+ 2,820 mm (26 mm increase since 7:00 on March 10)	O.P.+ 2,698 mm (29 mm increase since 7:00 on March 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,507 mm (Increase from initial level:5,724 mm, 13 mm increase since 7:00 on March 10) O.P.+ 3,499 mm (Increase from initial level:4,225 mm, 2 mm decrease since 7:00 on March 10) O.P.+ 4,385 mm (Water level from floor:589 mm, 7 mm increase since 7:00 on March 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	—	(From 10:00 on March 10 to 15:00 on March 10)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:02 on March 9 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.