

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 12)**

Water Level of the accumulated water (at 7:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,440 mm (18 mm decrease since 7:00 on March 11)	O.P.+ 2,726 mm (5 mm decrease since 7:00 on March 11)	—
	Water level of Turbine Building	O.P.+ 2,776 mm (32 mm increase since 7:00 on March 11)	O.P.+ 2,654 mm (2 mm decrease since 7:00 on March 11)	※ No data has been obtained due to the flaw in water level indicator.	O.P.+ 2,724 mm (20 mm increase since 7:00 on March 11)
	Water level of Reactor Building	O.P.+ 4,623 mm (7 mm increase since 7:00 on March 11)	O.P.+ 2,766 mm (24 mm decrease since 7:00 on March 11)	O.P.+ 2,793 mm (27 mm decrease since 7:00 on March 11)	O.P.+ 2,714 mm (16 mm increase since 7:00 on March 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,550 mm (Increase from initial level:5,767 mm, 43 mm increase since 7:00 on March 11) O.P.+ 3,505 mm (Increase from initial level:4,231 mm, 6 mm increase since 7:00 on March 11) O.P.+ 4,386 mm (Water level from floor:590 mm, 1 mm increase since 7:00 on March 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:48 on March 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank — (From 10:00 on March 11 to 15:00 on March 11)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:54 on March 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.