

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 13)**

Water Level of the accumulated water (at 7:00 on March 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,259 mm (181 mm decrease since 7:00 on March 12)	O.P.+ 2,705 mm (21 mm decrease since 7:00 on March 12)	—
	Water level of Turbine Building	O.P.+ 2,816 mm (40 mm increase since 7:00 on March 12)	O.P.+ 2,652 mm (2 mm decrease since 7:00 on March 12)	O.P.+ 2,723 mm (19 mm decrease since 7:00 on March 12)	O.P.+ 2,723 mm (1 mm decrease since 7:00 on March 12)
	Water level of Reactor Building	O.P.+ 4,611 mm (12 mm decrease since 7:00 on March 12)	O.P.+ 2,754 mm (12 mm decrease since 7:00 on March 12)	O.P.+ 2,764 mm (29 mm decrease since 7:00 on March 12)	O.P.+ 2,715 mm (1 mm increase since 7:00 on March 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,597 mm (Increase from initial level:5,814 mm, 47 mm increase since 7:00 on March 12) O.P.+ 3,507 mm (Increase from initial level:4,233 mm, 2 mm increase since 7:00 on March 12) O.P.+ 4,387 mm (Water level from floor:591 mm, 1 mm increase since 7:00 on March 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:48 on March 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on March 12 to 15:00 on March 12)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:54 on March 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.