

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 14)**

Water Level of the accumulated water (at 7:00 on March 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,262 mm (3 mm increase since 7:00 on March 13)	O.P.+ 2,705 mm (No change since 7:00 on March 13)	—
	Water level of Turbine Building	O.P.+ 2,850 mm (34 mm increase since 7:00 on March 13)	O.P.+ 2,643 mm (9 mm decrease since 7:00 on March 13)	O.P.+ 2,705 mm (18 mm decrease since 7:00 on March 13)	O.P.+ 2,723 mm (No change since 7:00 on March 13)
	Water level of Reactor Building	O.P.+ 4,593 mm (18 mm decrease since 7:00 on March 13)	O.P.+ 2,748 mm (6 mm decrease since 7:00 on March 13)	O.P.+ 2,742 mm (22 mm decrease since 7:00 on March 13)	O.P.+ 2,716 mm (1 mm increase since 7:00 on March 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,649 mm (Increase from initial level:5,866 mm, 52 mm increase since 7:00 on March 13) O.P.+ 3,498 mm (Increase from initial level:4,224 mm, 9 mm decrease since 7:00 on March 13) O.P.+ 4,390 mm (Water level from floor:594 mm, 3 mm increase since 7:00 on March 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:48 on March 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on March 13 to 15:00 on March 13)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:54 on March 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.