

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 15)**

Water Level of the accumulated water (at 7:00 on March 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,263 mm (1 mm increase since 7:00 on March 14)	O.P.+ 2,715 mm (10 mm increase since 7:00 on March 14)	—
	Water level of Turbine Building	O.P.+ 2,880 mm (30 mm increase since 7:00 on March 14)	O.P.+ 2,630 mm (13 mm decrease since 7:00 on March 14)	O.P.+ 2,755 mm (50 mm increase since 7:00 on March 14)	O.P.+ 2,723 mm (No change since 7:00 on March 14)
	Water level of Reactor Building	O.P.+ 4,576 mm (17 mm decrease since 7:00 on March 14)	O.P.+ 2,735 mm (13 mm decrease since 7:00 on March 14)	O.P.+ 2,786 mm (44 mm increase since 7:00 on March 14)	O.P.+ 2,715 mm (1 mm decrease since 7:00 on March 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,507 mm (Increase from initial level:5,724 mm, 142 mm decrease since 7:00 on March 14) O.P.+ 3,495 mm (Increase from initial level:4,221 mm, 3 mm decrease since 7:00 on March 14) O.P.+ 4,390 mm (Water level from floor:594 mm, No change since 7:00 on March 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:48 on March 11 to 10:04 on March 14)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:54 on March 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.