

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 17)**

Water Level of the accumulated water (at 7:00 on March 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,275 mm (7 mm increase since 7:00 on March 16)	O.P.+ 2,755 mm (18 mm increase since 7:00 on March 16)	—
	Water level of Turbine Building	O.P.+ 2,931 mm (24 mm increase since 7:00 on March 16)	O.P.+ 2,609 mm (11 mm decrease since 7:00 on March 16)	O.P.+ 2,807 mm (22 mm increase since 7:00 on March 16)	O.P.+ 2,749 mm (17 mm increase since 7:00 on March 16)
	Water level of Reactor Building	O.P.+ 4,530 mm (23 mm decrease since 7:00 on March 16)	O.P.+ 2,729 mm (4 mm decrease since 7:00 on March 16)	O.P.+ 2,847 mm (28 mm increase since 7:00 on March 16)	O.P.+ 2,733 mm (10 mm increase since 7:00 on March 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,330 mm (Increase from initial level:5,547 mm, 9 mm decrease since 7:00 on March 16) O.P.+ 3,510 mm (Increase from initial level:4,236 mm, 15 mm increase since 7:00 on March 16) O.P.+ 4,393 mm (Water level from floor:597 mm, 2 mm increase since 7:00 on March 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on March 16 to 15:00 on March 16)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:01 on March 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.