

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 18)**

Water Level of the accumulated water (at 7:00 on March 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,282 mm (7 mm increase since 7:00 on March 17)	O.P.+ 2,792 mm (37 mm increase since 7:00 on March 17)	—
	Water level of Turbine Building	O.P.+ 2,945 mm (14 mm increase since 7:00 on March 17)	O.P.+ 2,600 mm (9 mm decrease since 7:00 on March 17)	O.P.+ 2,838 mm (31 mm increase since 7:00 on March 17)	O.P.+ 2,774 mm (25 mm increase since 7:00 on March 17)
	Water level of Reactor Building	O.P.+ 4,508 mm (22 mm decrease since 7:00 on March 17)	O.P.+ 2,719 mm (10 mm decrease since 7:00 on March 17)	O.P.+ 2,883 mm (36 mm increase since 7:00 on March 17)	O.P.+ 2,746 mm (13 mm increase since 7:00 on March 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,341 mm (Increase from initial level:5,558 mm, 11 mm increase since 7:00 on March 17) O.P.+ 3,572 mm (Increase from initial level:4,298 mm, 62 mm increase since 7:00 on March 17) O.P.+ 4,396 mm (Water level from floor:600 mm, 3 mm increase since 7:00 on March 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 6:25 on March 18)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:01 on March 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.