

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 19)**

Water Level of the accumulated water (at 7:00 on March 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,278 mm (4 mm decrease since 7:00 on March 18)	O.P.+ 2,803 mm (11 mm increase since 7:00 on March 18)	—
	Water level of Turbine Building	O.P.+ 2,548 mm (397 mm decrease since 7:00 on March 18)	O.P.+ 2,610 mm (10 mm increase since 7:00 on March 18)	O.P.+ 2,854 mm (16 mm increase since 7:00 on March 18)	O.P.+ 2,793 mm (19 mm increase since 7:00 on March 18)
	Water level of Reactor Building	O.P.+ 4,496 mm (12 mm decrease since 7:00 on March 18)	O.P.+ 2,725 mm (6 mm increase since 7:00 on March 18)	O.P.+ 2,905 mm (22 mm increase since 7:00 on March 18)	O.P.+ 2,762 mm (16 mm increase since 7:00 on March 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,352 mm (Increase from initial level:5,569 mm, 11 mm increase since 7:00 on March 18) O.P.+ 3,385 mm (Increase from initial level:4,111 mm, 187 mm decrease since 7:00 on March 18) O.P.+ 4,397 mm (Water level from floor:601 mm, 1 mm increase since 7:00 on March 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 6:25 on March 18 to 18:28 on March 18)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on March 18 to 15:00 on March 18)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:01 on March 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.