

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 21)**

Water Level of the accumulated water (at 7:00 on March 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,268 mm (2 mm decrease since 7:00 on March 20)	O.P.+ 2,774 mm (29 mm decrease since 7:00 on March 20)	—
	Water level of Turbine Building	O.P.+ 2,607 mm (22 mm increase since 7:00 on March 20)	O.P.+ 2,598 mm (7 mm decrease since 7:00 on March 20)	O.P.+ 2,811 mm (40 mm decrease since 7:00 on March 20)	O.P.+ 2,805 mm (7 mm decrease since 7:00 on March 20)
	Water level of Reactor Building	O.P.+ 4,496 mm (10 mm decrease since 7:00 on March 20)	O.P.+ 2,713 mm (14 mm decrease since 7:00 on March 20)	O.P.+ 2,854 mm (53 mm decrease since 7:00 on March 20)	O.P.+ 2,792 mm (13 mm increase since 7:00 on March 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,361 mm (Increase from initial level:5,578 mm, 48 mm increase since 7:00 on March 20) O.P.+ 3,060 mm (Increase from initial level:3,786 mm, 150 mm decrease since 7:00 on March 20) O.P.+ 4,400 mm (Water level from floor:604 mm, 2 mm increase since 7:00 on March 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:38 on March 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building Temporary Tank	Transfer Completed	(From 10:00 on March 20 to 15:00 on March 20)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:37 on March 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.