

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 22)**

Water Level of the accumulated water (at 7:00 on March 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,269 mm (1 mm increase since 7:00 on March 21)	O.P.+ 2,756 mm (18 mm decrease since 7:00 on March 21)	—
	Water level of Turbine Building	O.P.+ 2,627 mm (20 mm increase since 7:00 on March 21)	O.P.+ 2,588 mm (10 mm decrease since 7:00 on March 21)	O.P.+ 2,783 mm (28 mm decrease since 7:00 on March 21)	O.P.+ 2,799 mm (6 mm decrease since 7:00 on March 21)
	Water level of Reactor Building	O.P.+ 4,482 mm (14 mm decrease since 7:00 on March 21)	O.P.+ 2,703 mm (10 mm decrease since 7:00 on March 21)	O.P.+ 2,823 mm (31 mm decrease since 7:00 on March 21)	O.P.+ 2,785 mm (7 mm decrease since 7:00 on March 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,409 mm (Increase from initial level:5,626 mm, 48 mm increase since 7:00 on March 21) O.P.+ 2,927 mm (Increase from initial level:3,653 mm, 133 mm decrease since 7:00 on March 21) O.P.+ 4,400 mm (Water level from floor:604 mm, No change since 7:00 on March 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:38 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:37 on March 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:56 on March 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.