

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 23)**

Water Level of the accumulated water (at 7:00 on March 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,270 mm (1 mm increase since 7:00 on March 22)	O.P.+ 2,731 mm (25 mm decrease since 7:00 on March 22)	—
	Water level of Turbine Building	O.P.+ 2,648 mm (21 mm increase since 7:00 on March 22)	O.P.+ 2,576 mm (12 mm decrease since 7:00 on March 22)	O.P.+ 2,760 mm (23 mm decrease since 7:00 on March 22)	O.P.+ 2,781 mm (18 mm decrease since 7:00 on March 22)
	Water level of Reactor Building	O.P.+ 4,464 mm (18 mm decrease since 7:00 on March 22)	O.P.+ 2,695 mm (8 mm decrease since 7:00 on March 22)	O.P.+ 2,794 mm (29 mm decrease since 7:00 on March 22)	O.P.+ 2,773 mm (12 mm decrease since 7:00 on March 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,457 mm (Increase from initial level:5,674 mm, 48 mm increase since 7:00 on March 22) O.P.+ 2,811 mm (Increase from initial level:3,537 mm, 116 mm decrease since 7:00 on March 22) O.P.+ 4,402 mm (Water level from floor:606 mm, 2 mm increase since 7:00 on March 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:38 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:59 on March 23   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:36 on March 23   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.