

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 24)**

Water Level of the accumulated water (at 7:00 on March 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,273 mm (3 mm increase since 7:00 on March 23)	O.P.+ 2,704 mm (27 mm decrease since 7:00 on March 23)	—
	Water level of Turbine Building	O.P.+ 2,667 mm (19 mm increase since 7:00 on March 23)	O.P.+ 2,655 mm (79 mm increase since 7:00 on March 23)	O.P.+ 2,737 mm (23 mm decrease since 7:00 on March 23)	O.P.+ 2,763 mm (18 mm decrease since 7:00 on March 23)
	Water level of Reactor Building	O.P.+ 4,451 mm (13 mm decrease since 7:00 on March 23)	O.P.+ 2,727 mm (32 mm increase since 7:00 on March 23)	O.P.+ 2,765 mm (29 mm decrease since 7:00 on March 23)	O.P.+ 2,759 mm (14 mm decrease since 7:00 on March 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,674 mm (Increase from initial level:5,891 mm, 217 mm increase since 7:00 on March 23) O.P.+ 2,855 mm (Increase from initial level:3,581 mm, 44 mm increase since 7:00 on March 23) O.P.+ 4,402 mm (Water level from floor:606 mm, No change since 7:00 on March 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:25 on March 2 to 9:59 on March 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:38 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:59 on March 23 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:36 on March 23 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.