

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 26)**

Water Level of the accumulated water (at 7:00 on March 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,275 mm (2 mm increase since 7:00 on March 25)	O.P.+ 2,675 mm (25 mm decrease since 7:00 on March 25)	—
	Water level of Turbine Building	O.P.+ 2,696 mm (14 mm increase since 7:00 on March 25)	O.P.+ 2,795 mm (68 mm increase since 7:00 on March 25)	O.P.+ 2,702 mm (21 mm decrease since 7:00 on March 25)	O.P.+ 2,735 mm (20 mm decrease since 7:00 on March 25)
	Water level of Reactor Building	O.P.+ 4,441 mm (3 mm decrease since 7:00 on March 25)	O.P.+ 2,860 mm (65 mm increase since 7:00 on March 25)	O.P.+ 2,721 mm (38 mm decrease since 7:00 on March 25)	O.P.+ 2,736 mm (16 mm decrease since 7:00 on March 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,782 mm (Increase from initial level:5,999 mm, 42 mm increase since 7:00 on March 25) O.P.+ 2,381 mm (Increase from initial level:3,107 mm, 425 mm decrease since 7:00 on March 25) O.P.+ 4,403 mm (Water level from floor:607 mm, No change since 7:00 on March 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:38 on March 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:07 on March 25 to 15:00 on March 25)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:05 on March 24 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.