

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 28)**

Water Level of the accumulated water (at 7:00 on March 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,281 mm (4 mm increase since 7:00 on March 27)	O.P.+ 2,715 mm (36 mm increase since 7:00 on March 27)	—
	Water level of Turbine Building	O.P.+ 2,398 mm (11 mm increase since 7:00 on March 27)	O.P.+ 2,770 mm (15 mm decrease since 7:00 on March 27)	O.P.+ 2,794 mm (43 mm increase since 7:00 on March 27)	O.P.+ 2,741 mm (18 mm increase since 7:00 on March 27)
	Water level of Reactor Building	O.P.+ 4,439 mm (5 mm decrease since 7:00 on March 27)	O.P.+ 2,880 mm (7 mm decrease since 7:00 on March 27)	O.P.+ 2,818 mm (50 mm increase since 7:00 on March 27)	O.P.+ 2,736 mm (14 mm increase since 7:00 on March 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,512 mm (Increase from initial level:5,729 mm, 160 mm decrease since 7:00 on March 27) O.P.+ 2,072 mm (Increase from initial level:2,798 mm, 122 mm decrease since 7:00 on March 27) O.P.+ 4,405 mm (Water level from floor:609 mm, No change since 7:00 on March 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on March 27 to 15:00 on March 27)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:05 on March 24 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.