

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 29)**

Water Level of the accumulated water (at 7:00 on March 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,283 mm (2 mm increase since 7:00 on March 28)	O.P.+ 2,734 mm (19 mm increase since 7:00 on March 28)	—
	Water level of Turbine Building	O.P.+ 2,408 mm (10 mm increase since 7:00 on March 28)	O.P.+ 2,754 mm (16 mm decrease since 7:00 on March 28)	O.P.+ 2,815 mm (21 mm increase since 7:00 on March 28)	O.P.+ 2,754 mm (13 mm increase since 7:00 on March 28)
	Water level of Reactor Building	O.P.+ 4,435 mm (4 mm decrease since 7:00 on March 28)	O.P.+ 2,866 mm (14 mm decrease since 7:00 on March 28)	O.P.+ 2,844 mm (26 mm increase since 7:00 on March 28)	O.P.+ 2,745 mm (9 mm increase since 7:00 on March 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,496 mm (Increase from initial level:5,713 mm, 16 mm decrease since 7:00 on March 28) O.P.+ 1,956 mm (Increase from initial level:2,682 mm, 116 mm decrease since 7:00 on March 28) O.P.+ 4,407 mm (Water level from floor:611 mm, 2 mm increase since 7:00 on March 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:01 on March 28   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.