

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 30)**

| | | | | | |
|---|--|--|--|---|---|
| Water Level of the accumulated water (at 7:00 on March 30) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 2,286 mm (3 mm increase since 7:00 on March 29) | O.P.+ 2,752 mm (18 mm increase since 7:00 on March 29) | — |
| | Water level of Turbine Building | O.P.+ 2,418 mm (10 mm increase since 7:00 on March 29) | O.P.+ 2,738 mm (16 mm decrease since 7:00 on March 29) | O.P.+ 2,833 mm (18 mm increase since 7:00 on March 29) | O.P.+ 2,770 mm (16 mm increase since 7:00 on March 29) |
| | Water level of Reactor Building | O.P.+ 4,436 mm (1 mm increase since 7:00 on March 29) | O.P.+ 2,852 mm (14 mm decrease since 7:00 on March 29) | O.P.+ 2,869 mm (25 mm increase since 7:00 on March 29) | O.P.+ 2,756 mm (11 mm increase since 7:00 on March 29) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,500 mm (Increase from initial level:5,717 mm, 4 mm increase since 7:00 on March 29) O.P.+ 1,840 mm (Increase from initial level:2,566 mm, 116 mm decrease since 7:00 on March 29) O.P.+ 4,409 mm (Water level from floor:613 mm, 2 mm increase since 7:00 on March 29) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26) | — | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 10:01 on March 28 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.