

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 31)**

Water Level of the accumulated water (at 7:00 on March 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,278 mm (8 mm decrease since 7:00 on March 30)	O.P.+ 2,767 mm (15 mm increase since 7:00 on March 30)	—
	Water level of Turbine Building	O.P.+ 2,424 mm (6 mm increase since 7:00 on March 30)	O.P.+ 2,726 mm (12 mm decrease since 7:00 on March 30)	O.P.+ 2,849 mm (16 mm increase since 7:00 on March 30)	O.P.+ 2,785 mm (15 mm increase since 7:00 on March 30)
	Water level of Reactor Building	O.P.+ 4,429 mm (7 mm decrease since 7:00 on March 30)	O.P.+ 2,836 mm (16 mm decrease since 7:00 on March 30)	O.P.+ 2,886 mm (17 mm increase since 7:00 on March 30)	O.P.+ 2,766 mm (10 mm increase since 7:00 on March 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,392 mm (Increase from initial level:5,609 mm, 108 mm decrease since 7:00 on March 30) O.P.+ 1,733 mm (Increase from initial level:2,459 mm, 107 mm decrease since 7:00 on March 30) O.P.+ 4,410 mm (Water level from floor:614 mm, 1 mm increase since 7:00 on March 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:30 on March 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.