

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 1)**

Water Level of the accumulated water (at 7:00 on April 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,278 mm (No change since 7:00 on March 31)	O.P.+ 2,783 mm (16 mm increase since 7:00 on March 31)	—
	Water level of Turbine Building	O.P.+ 2,430 mm (6 mm increase since 7:00 on March 31)	O.P.+ 2,709 mm (17 mm decrease since 7:00 on March 31)	O.P.+ 2,866 mm (17 mm increase since 7:00 on March 31)	O.P.+ 2,802 mm (17 mm increase since 7:00 on March 31)
	Water level of Reactor Building	O.P.+ 4,427 mm (2 mm decrease since 7:00 on March 31)	O.P.+ 2,827 mm (9 mm decrease since 7:00 on March 31)	O.P.+ 2,906 mm (20 mm increase since 7:00 on March 31)	O.P.+ 2,777 mm (11 mm increase since 7:00 on March 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,239 mm (Increase from initial level:5,456 mm, 153 mm decrease since 7:00 on March 31) O.P.+ 1,634 mm (Increase from initial level:2,360 mm, 99 mm decrease since 7:00 on March 31) O.P.+ 4,411 mm (Water level from floor:615 mm, 1 mm increase since 7:00 on March 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:30 on March 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.