

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 2)**

Water Level of the accumulated water (at 7:00 on April 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,280 mm (2 mm increase since 7:00 on April 1)	O.P.+ 2,762 mm (21 mm decrease since 7:00 on April 1)	—
	Water level of Turbine Building	O.P.+ 2,437 mm (7 mm increase since 7:00 on April 1)	O.P.+ 2,698 mm (11 mm decrease since 7:00 on April 1)	O.P.+ 2,822 mm (44 mm decrease since 7:00 on April 1)	O.P.+ 2,803 mm (1 mm increase since 7:00 on April 1)
	Water level of Reactor Building	O.P.+ 4,428 mm (1 mm increase since 7:00 on April 1)	O.P.+ 2,810 mm (17 mm decrease since 7:00 on April 1)	O.P.+ 2,862 mm (44 mm decrease since 7:00 on April 1)	O.P.+ 2,788 mm (11 mm increase since 7:00 on April 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,271 mm (Increase from initial level:5,488 mm, 32 mm increase since 7:00 on April 1) O.P.+ 1,556 mm (Increase from initial level:2,282 mm, 78 mm decrease since 7:00 on April 1) O.P.+ 4,413 mm (Water level from floor:617 mm, 2 mm increase since 7:00 on April 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:20 on April 1)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:30 on March 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on March 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.