

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 3)**

Water Level of the accumulated water (at 7:00 on April 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,282 mm (2 mm increase since 7:00 on April 2)	O.P.+ 2,566 mm (196 mm decrease since 7:00 on April 2)	—
	Water level of Turbine Building	O.P.+ 2,442 mm (5 mm increase since 7:00 on April 2)	O.P.+ 2,684 mm (14 mm decrease since 7:00 on April 2)	O.P.+ 2,818 mm (4 mm decrease since 7:00 on April 2)	O.P.+ 2,810 mm (7 mm increase since 7:00 on April 2)
	Water level of Reactor Building	O.P.+ 4,442 mm (14 mm increase since 7:00 on April 2)	O.P.+ 2,798 mm (12 mm decrease since 7:00 on April 2)	O.P.+ 2,858 mm (4 mm decrease since 7:00 on April 2)	O.P.+ 2,795 mm (7 mm increase since 7:00 on April 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,340 mm (Increase from initial level:5,557 mm, 69 mm increase since 7:00 on April 2) O.P.+ 1,622 mm (Increase from initial level:2,348 mm, 66 mm increase since 7:00 on April 2) O.P.+ 4,413 mm (Water level from floor:617 mm, No change since 7:00 on April 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:20 on April 1)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 2 to 15:00 on April 2)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on April 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:14 on April 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.