

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 6)**

Water Level of the accumulated water (at 7:00 on April 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,287 mm (4 mm increase since 7:00 on April 5)	O.P.+ 2,566 mm (13 mm decrease since 7:00 on April 5)	—
	Water level of Turbine Building	O.P.+ 2,450 mm (4 mm increase since 7:00 on April 5)	O.P.+ 2,655 mm (11 mm decrease since 7:00 on April 5)	O.P.+ 2,730 mm (25 mm decrease since 7:00 on April 5)	O.P.+ 2,764 mm (18 mm decrease since 7:00 on April 5)
	Water level of Reactor Building	O.P.+ 4,420 mm (10 mm decrease since 7:00 on April 5)	O.P.+ 2,769 mm (1 mm decrease since 7:00 on April 5)	O.P.+ 2,751 mm (31 mm decrease since 7:00 on April 5)	O.P.+ 2,763 mm (13 mm decrease since 7:00 on April 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,546 mm (Increase from initial level:5,763 mm, 59 mm increase since 7:00 on April 5) O.P.+ 1,684 mm (Increase from initial level:2,410 mm, 22 mm increase since 7:00 on April 5) O.P.+ 4,418 mm (Water level from floor:622 mm, 2 mm increase since 7:00 on April 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:20 on April 1)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:14 on April 3 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:14 on April 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.