

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 7)**

Water Level of the accumulated water (at 7:00 on April 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,288 mm (1 mm increase since 7:00 on April 6)	O.P.+ 2,597 mm (31 mm increase since 7:00 on April 6)	—
	Water level of Turbine Building	O.P.+ 2,453 mm (3 mm increase since 7:00 on April 6)	O.P.+ 2,642 mm (13 mm decrease since 7:00 on April 6)	O.P.+ 2,777 mm (47 mm increase since 7:00 on April 6)	O.P.+ 2,751 mm (13 mm decrease since 7:00 on April 6)
	Water level of Reactor Building	O.P.+ 4,406 mm (14 mm decrease since 7:00 on April 6)	O.P.+ 2,753 mm (16 mm decrease since 7:00 on April 6)	O.P.+ 2,801 mm (50 mm increase since 7:00 on April 6)	O.P.+ 2,751 mm (12 mm decrease since 7:00 on April 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,425 mm (Increase from initial level:5,642 mm, 121 mm decrease since 7:00 on April 6) O.P.+ 1,716 mm (Increase from initial level:2,442 mm, 32 mm increase since 7:00 on April 6) O.P.+ 4,418 mm (Water level from floor:622 mm, No change since 7:00 on April 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 11:20 on April 1 to 9:52 on April 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:14 on April 3 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:14 on April 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.