

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 8)**

Water Level of the accumulated water (at 7:00 on April 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,289 mm (1 mm increase since 7:00 on April 7)	O.P.+ 2,644 mm (47 mm increase since 7:00 on April 7)	—
	Water level of Turbine Building	O.P.+ 2,451 mm (2 mm decrease since 7:00 on April 7)	O.P.+ 2,625 mm (17 mm decrease since 7:00 on April 7)	O.P.+ 2,805 mm (28 mm increase since 7:00 on April 7)	O.P.+ 2,756 mm (5 mm increase since 7:00 on April 7)
	Water level of Reactor Building	O.P.+ 4,395 mm (11 mm decrease since 7:00 on April 7)	O.P.+ 2,733 mm (20 mm decrease since 7:00 on April 7)	O.P.+ 2,839 mm (38 mm increase since 7:00 on April 7)	O.P.+ 2,753 mm (2 mm increase since 7:00 on April 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,420 mm (Increase from initial level:5,637 mm, 5 mm decrease since 7:00 on April 7) O.P.+ 1,763 mm (Increase from initial level:2,489 mm, 47 mm increase since 7:00 on April 7) O.P.+ 4,418 mm (Water level from floor:622 mm, No change since 7:00 on April 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 6:32 on April 8)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 26)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on April 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:14 on April 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.