

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 10)**

Water Level of the accumulated water (at 7:00 on April 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,373 mm (917 mm decrease since 7:00 on April 9)	O.P.+ 2,774 mm (46 mm increase since 7:00 on April 9)	—
	Water level of Turbine Building	O.P.+ 2,421 mm (72 mm increase since 7:00 on April 9)	O.P.+ 2,688 mm (78 mm increase since 7:00 on April 9)	O.P.+ 2,748 mm (38 mm decrease since 7:00 on April 9)	O.P.+ 2,758 mm (9 mm decrease since 7:00 on April 9)
	Water level of Reactor Building	O.P.+ 4,369 mm (12 mm decrease since 7:00 on April 9)	O.P.+ 2,761 mm (41 mm increase since 7:00 on April 9)	O.P.+ 2,779 mm (42 mm decrease since 7:00 on April 9)	O.P.+ 2,755 mm (7 mm decrease since 7:00 on April 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,533 mm (Increase from initial level:5,750 mm, 63 mm increase since 7:00 on April 9) O.P.+ 1,875 mm (Increase from initial level:2,601 mm, 75 mm increase since 7:00 on April 9) O.P.+ 4,421 mm (Water level from floor:625 mm, 3 mm increase since 7:00 on April 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:14 on March 26 to 10:02 on April 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:08 on April 8)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 9 to 15:00 on April 9)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:35 on April 8 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:28 on April 9 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.