

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 11)**

Water Level of the accumulated water (at 7:00 on April 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,374 mm (1 mm increase since 7:00 on April 10)	O.P.+ 2,784 mm (10 mm increase since 7:00 on April 10)	—
	Water level of Turbine Building	O.P.+ 2,430 mm (9 mm increase since 7:00 on April 10)	O.P.+ 2,650 mm (38 mm decrease since 7:00 on April 10)	O.P.+ 2,805 mm (57 mm increase since 7:00 on April 10)	O.P.+ 2,754 mm (4 mm decrease since 7:00 on April 10)
	Water level of Reactor Building	O.P.+ 4,385 mm (16 mm increase since 7:00 on April 10)	O.P.+ 2,784 mm (23 mm increase since 7:00 on April 10)	O.P.+ 2,837 mm (58 mm increase since 7:00 on April 10)	O.P.+ 2,750 mm (5 mm decrease since 7:00 on April 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,594 mm (Increase from initial level:5,811 mm, 61 mm increase since 7:00 on April 10) O.P.+ 1,421 mm (Increase from initial level:2,147 mm, 454 mm decrease since 7:00 on April 10) O.P.+ 4,422 mm (Water level from floor:626 mm, 1 mm increase since 7:00 on April 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:35 on April 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:08 on April 8)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 10 to 15:00 on April 10)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:35 on April 8 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 10:40 on April 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.