

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 12)**

Water Level of the accumulated water (at 7:00 on April 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,437 mm (63 mm increase since 7:00 on April 11)	O.P.+ 2,787 mm (3 mm increase since 7:00 on April 11)	—
	Water level of Turbine Building	O.P.+ 2,530 mm (100 mm increase since 7:00 on April 11)	O.P.+ 2,649 mm (1 mm decrease since 7:00 on April 11)	O.P.+ 2,771 mm (34 mm decrease since 7:00 on April 11)	O.P.+ 2,758 mm (4 mm increase since 7:00 on April 11)
	Water level of Reactor Building	O.P.+ 4,448 mm (63 mm increase since 7:00 on April 11)	O.P.+ 2,771 mm (13 mm decrease since 7:00 on April 11)	O.P.+ 2,800 mm (37 mm decrease since 7:00 on April 11)	O.P.+ 2,755 mm (5 mm increase since 7:00 on April 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,477 mm (Increase from initial level:5,694 mm, 117 mm decrease since 7:00 on April 11) O.P.+ 1,662 mm (Increase from initial level:2,388 mm, 241 mm increase since 7:00 on April 11) O.P.+ 4,425 mm (Water level from floor:629 mm, 3 mm increase since 7:00 on April 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:00 on April 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:33 on April 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:35 on April 8 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 10:40 on April 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.