

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 13)**

Water Level of the accumulated water (at 7:00 on April 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,499 mm (62 mm increase since 7:00 on April 12)	O.P.+ 2,783 mm (4 mm decrease since 7:00 on April 12)	—
	Water level of Turbine Building	O.P.+ 2,543 mm (13 mm increase since 7:00 on April 12)	O.P.+ 2,638 mm (11 mm decrease since 7:00 on April 12)	O.P.+ 2,736 mm (35 mm decrease since 7:00 on April 12)	O.P.+ 2,750 mm (8 mm decrease since 7:00 on April 12)
	Water level of Reactor Building	O.P.+ 4,471 mm (23 mm increase since 7:00 on April 12)	O.P.+ 2,747 mm (24 mm decrease since 7:00 on April 12)	O.P.+ 2,761 mm (39 mm decrease since 7:00 on April 12)	O.P.+ 2,749 mm (6 mm decrease since 7:00 on April 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,462 mm (Increase from initial level:5,679 mm, 15 mm decrease since 7:00 on April 12) O.P.+ 2,092 mm (Increase from initial level:2,818 mm, 430 mm increase since 7:00 on April 12) O.P.+ 4,426 mm (Water level from floor:630 mm, 1 mm increase since 7:00 on April 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:00 on April 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:33 on April 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:52 on April 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:40 on April 10   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*At 9:52 AM on April 12, we temporarily stopped the Cesium Adsorption Apparatus for absorbance tower replacement.				

※ For quick publication of the data of water level, values are provided as reference values.