

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 14)**

Water Level of the accumulated water (at 7:00 on April 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,563 mm (64 mm increase since 7:00 on April 13)	O.P.+ 2,786 mm (3 mm increase since 7:00 on April 13)	—
	Water level of Turbine Building	O.P.+ 2,576 mm (33 mm increase since 7:00 on April 13)	O.P.+ 2,705 mm (67 mm increase since 7:00 on April 13)	O.P.+ 2,787 mm (51 mm increase since 7:00 on April 13)	O.P.+ 2,744 mm (6 mm decrease since 7:00 on April 13)
	Water level of Reactor Building	O.P.+ 4,536 mm (65 mm increase since 7:00 on April 13)	O.P.+ 2,797 mm (50 mm increase since 7:00 on April 13)	O.P.+ 2,817 mm (56 mm increase since 7:00 on April 13)	O.P.+ 2,743 mm (6 mm decrease since 7:00 on April 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,470 mm (Increase from initial level:5,687 mm, 8 mm increase since 7:00 on April 13) O.P.+ 1,708 mm (Increase from initial level:2,434 mm, 384 mm decrease since 7:00 on April 13) O.P.+ 4,429 mm (Water level from floor:633 mm, 3 mm increase since 7:00 on April 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:00 on April 11 to 10:14 on April 13)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:33 on April 11 to 9:48 on April 13)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 13 to 15:00 on April 13)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:52 on April 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on April 14 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.