

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 15)**

Water Level of the accumulated water (at 7:00 on April 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,631 mm (68 mm increase since 7:00 on April 14)	O.P.+ 2,791 mm (5 mm increase since 7:00 on April 14)	—
	Water level of Turbine Building	O.P.+ 2,617 mm (41 mm increase since 7:00 on April 14)	O.P.+ 2,710 mm (5 mm increase since 7:00 on April 14)	O.P.+ 2,765 mm (22 mm decrease since 7:00 on April 14)	O.P.+ 2,748 mm (4 mm increase since 7:00 on April 14)
	Water level of Reactor Building	O.P.+ 4,614 mm (78 mm increase since 7:00 on April 14)	O.P.+ 2,844 mm (47 mm increase since 7:00 on April 14)	O.P.+ 2,802 mm (15 mm decrease since 7:00 on April 14)	O.P.+ 2,746 mm (3 mm increase since 7:00 on April 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,476 mm (Increase from initial level:5,693 mm, 6 mm increase since 7:00 on April 14) O.P.+ 2,281 mm (Increase from initial level:3,007 mm, 573 mm increase since 7:00 on April 14) O.P.+ 4,432 mm (Water level from floor:636 mm, 3 mm increase since 7:00 on April 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:49 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:34 on April 14)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:52 on April 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 22:08 on April 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.