

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 17)**

Water Level of the accumulated water (at 7:00 on April 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,744 mm (50 mm increase since 7:00 on April 16)	O.P.+ 1,810 mm (985 mm decrease since 7:00 on April 16)	—
	Water level of Turbine Building	O.P.+ 2,533 mm (88 mm decrease since 7:00 on April 16)	O.P.+ 2,706 mm (3 mm decrease since 7:00 on April 16)	O.P.+ 2,715 mm (22 mm decrease since 7:00 on April 16)	O.P.+ 2,731 mm (10 mm decrease since 7:00 on April 16)
	Water level of Reactor Building	O.P.+ 4,714 mm (44 mm increase since 7:00 on April 16)	O.P.+ 2,812 mm (21 mm decrease since 7:00 on April 16)	O.P.+ 2,736 mm (26 mm decrease since 7:00 on April 16)	O.P.+ 2,734 mm (8 mm decrease since 7:00 on April 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,493 mm (Increase from initial level:5,710 mm, 8 mm increase since 7:00 on April 16) O.P.+ 3,064 mm (Increase from initial level:3,790 mm, 423 mm increase since 7:00 on April 16) O.P.+ 4,441 mm (Water level from floor:645 mm, 3 mm increase since 7:00 on April 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 5:53 on April 16 to 11:53 on April 16)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:49 on April 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:34 on April 14)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 15 to 15:00 on April 15)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:52 on April 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 22:08 on April 14   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.