

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 19)**

|   |  |   |  |   |   |
|---|--|---|--|---|---|
| Water Level of the accumulated water<br>(at 7:00 on April 19) |  | Unit 1  | Unit 2   | Unit 3  | Unit 4  |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 1,823 mm<br>(38 mm increase since 7:00 on April 18)  | O.P.+ 1,808 mm<br>(2 mm decrease since 7:00 on April 18)  | —   |
|   | Water level of Turbine Building  | O.P.+ 2,653 mm<br>(26 mm increase since 7:00 on April 18)   | O.P.+ 2,854 mm<br>(77 mm increase since 7:00 on April 18)  | O.P.+ 2,790 mm<br>(30 mm increase since 7:00 on April 18) | O.P.+ 2,733 mm<br>(10 mm increase since 7:00 on April 18) |
|   | Water level of Reactor Building  | O.P.+ 4,726 mm<br>(3 mm increase since 7:00 on April 18)  | O.P.+ 2,914 mm<br>(70 mm increase since 7:00 on April 18)  | O.P.+ 2,816 mm<br>(34 mm increase since 7:00 on April 18) | O.P.+ 2,731 mm<br>(5 mm increase since 7:00 on April 18)  |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 4,501 mm (Increase from initial level:5,718 mm, 3 mm increase since 7:00 on April 18)<br>O.P.+ 2,044 mm (Increase from initial level:2,770 mm, 541 mm decrease since 7:00 on April 18)<br>O.P.+ 4,444 mm (Water level from floor:648 mm, 2 mm increase since 7:00 on April 18) |   |   |
| Situation of transfer of the accumulated water                |  | Unit 1  | Unit 2   | Unit 3  | Unit 4  |
|   |  | —   | —  | —   | —   |
|   |  | Unit 5 and 6  |  |   |   |
|   |  | —   |  |   |   |
| Operation condition of water treatment facility               |  | Cesium Adsorption Apparatus: Since 9:52 on April 12   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 22:08 on April 14   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |   |   |
| Notes   |  |   |  |   |   |

※ For quick publication of the data of water level, values are provided as reference values.