

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 20)**

Water Level of the accumulated water (at 7:00 on April 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,856 mm (33 mm increase since 7:00 on April 19)	O.P.+ 1,806 mm (2 mm decrease since 7:00 on April 19)	—
	Water level of Turbine Building	O.P.+ 2,673 mm (20 mm increase since 7:00 on April 19)	O.P.+ 2,805 mm (49 mm decrease since 7:00 on April 19)	O.P.+ 2,827 mm (37 mm increase since 7:00 on April 19)	O.P.+ 2,747 mm (14 mm increase since 7:00 on April 19)
	Water level of Reactor Building	O.P.+ 4,707 mm (19 mm decrease since 7:00 on April 19)	O.P.+ 2,919 mm (5 mm increase since 7:00 on April 19)	O.P.+ 2,857 mm (41 mm increase since 7:00 on April 19)	O.P.+ 2,738 mm (7 mm increase since 7:00 on April 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,691 mm (Increase from initial level:5,908 mm, 190 mm increase since 7:00 on April 19) O.P.+ 1,514 mm (Increase from initial level:2,240 mm, 530 mm decrease since 7:00 on April 19) O.P.+ 4,445 mm (Water level from floor:649 mm, 1 mm increase since 7:00 on April 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on April 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:46 on April 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:52 on April 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 22:08 on April 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.