

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 22)**

Water Level of the accumulated water (at 7:00 on April 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,916 mm (26 mm increase since 7:00 on April 21)	O.P.+ 1,799 mm (5 mm decrease since 7:00 on April 21)	—
	Water level of Turbine Building	O.P.+ 2,584 mm (92 mm decrease since 7:00 on April 21)	O.P.+ 2,777 mm (16 mm decrease since 7:00 on April 21)	O.P.+ 2,763 mm (27 mm decrease since 7:00 on April 21)	O.P.+ 2,759 mm (1 mm increase since 7:00 on April 21)
	Water level of Reactor Building	O.P.+ 4,655 mm (27 mm decrease since 7:00 on April 21)	O.P.+ 2,873 mm (31 mm decrease since 7:00 on April 21)	O.P.+ 2,789 mm (34 mm decrease since 7:00 on April 21)	O.P.+ 2,751 mm (2 mm increase since 7:00 on April 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,365 mm (Increase from initial level:5,582 mm, 192 mm decrease since 7:00 on April 21) O.P.+ 2,211 mm (Increase from initial level:2,937 mm, 461 mm increase since 7:00 on April 21) O.P.+ 4,449 mm (Water level from floor:653 mm, 2 mm increase since 7:00 on April 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 5:53 on April 21 to 11:47 on April 21)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:42 on April 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:38 on April 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:16 on April 20 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 22:08 on April 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.