

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 23)**

Water Level of the accumulated water (at 7:00 on April 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,941 mm (25 mm increase since 7:00 on April 22)	O.P.+ 1,794 mm (5 mm decrease since 7:00 on April 22)	—
	Water level of Turbine Building	O.P.+ 2,670 mm (86 mm increase since 7:00 on April 22)	O.P.+ 2,758 mm (19 mm decrease since 7:00 on April 22)	O.P.+ 2,731 mm (32 mm decrease since 7:00 on April 22)	O.P.+ 2,748 mm (11 mm decrease since 7:00 on April 22)
	Water level of Reactor Building	O.P.+ 4,635 mm (20 mm decrease since 7:00 on April 22)	O.P.+ 2,859 mm (14 mm decrease since 7:00 on April 22)	O.P.+ 2,752 mm (37 mm decrease since 7:00 on April 22)	O.P.+ 2,745 mm (6 mm decrease since 7:00 on April 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,196 mm (Increase from initial level:5,413 mm, 169 mm decrease since 7:00 on April 22) O.P.+ 2,676 mm (Increase from initial level:3,402 mm, 465 mm increase since 7:00 on April 22) O.P.+ 4,452 mm (Water level from floor:656 mm, 3 mm increase since 7:00 on April 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:42 on April 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:38 on April 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:16 on April 20 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 22:08 on April 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.