

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 25)**

Water Level of the accumulated water (at 7:00 on April 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,932 mm (5 mm decrease since 7:00 on April 24)	O.P.+ 1,786 mm (4 mm decrease since 7:00 on April 24)	—
	Water level of Turbine Building	O.P.+ 2,707 mm (17 mm increase since 7:00 on April 24)	O.P.+ 2,724 mm (34 mm decrease since 7:00 on April 24)	O.P.+ 2,764 mm (58 mm increase since 7:00 on April 24)	O.P.+ 2,723 mm (9 mm decrease since 7:00 on April 24)
	Water level of Reactor Building	O.P.+ 4,612 mm (9 mm decrease since 7:00 on April 24)	O.P.+ 2,838 mm (15 mm decrease since 7:00 on April 24)	O.P.+ 2,784 mm (60 mm increase since 7:00 on April 24)	O.P.+ 2,723 mm (10 mm decrease since 7:00 on April 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,191 mm (Increase from initial level:5,408 mm, 155 mm increase since 7:00 on April 24) O.P.+ 2,836 mm (Increase from initial level:3,562 mm, 506 mm decrease since 7:00 on April 24) O.P.+ 4,455 mm (Water level from floor:659 mm, 1 mm increase since 7:00 on April 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:56 on April 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:12 on April 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 24 to 15:00 on April 24)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:28 on April 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.