

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 26)**

Water Level of the accumulated water (at 7:00 on April 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,932 mm (No change since 7:00 on April 25)	O.P.+ 1,782 mm (4 mm decrease since 7:00 on April 25)	—
	Water level of Turbine Building	O.P.+ 2,718 mm (11 mm increase since 7:00 on April 25)	O.P.+ 2,676 mm (48 mm decrease since 7:00 on April 25)	O.P.+ 2,806 mm (42 mm increase since 7:00 on April 25)	O.P.+ 2,733 mm (10 mm increase since 7:00 on April 25)
	Water level of Reactor Building	O.P.+ 4,605 mm (7 mm decrease since 7:00 on April 25)	O.P.+ 2,796 mm (42 mm decrease since 7:00 on April 25)	O.P.+ 2,837 mm (53 mm increase since 7:00 on April 25)	O.P.+ 2,730 mm (7 mm increase since 7:00 on April 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,405 mm (Increase from initial level:5,622 mm, 214 mm increase since 7:00 on April 25) O.P.+ 2,349 mm (Increase from initial level:3,075 mm, 487 mm decrease since 7:00 on April 25) O.P.+ 4,456 mm (Water level from floor:660 mm, 1 mm increase since 7:00 on April 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 6:25 on April 26)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:56 on April 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 11:12 on April 24 to 5:49 on April 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:28 on April 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.