

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 28)**

Water Level of the accumulated water (at 7:00 on April 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,944 mm (10 mm increase since 7:00 on April 27)	O.P.+ 1,775 mm (3 mm decrease since 7:00 on April 27)	—
	Water level of Turbine Building	O.P.+ 2,429 mm (85 mm increase since 7:00 on April 27)	O.P.+ 2,639 mm (1 mm increase since 7:00 on April 27)	O.P.+ 2,865 mm (52 mm decrease since 7:00 on April 27)	O.P.+ 2,782 mm (28 mm increase since 7:00 on April 27)
	Water level of Reactor Building	O.P.+ 4,590 mm (7 mm decrease since 7:00 on April 27)	O.P.+ 2,746 mm (14 mm decrease since 7:00 on April 27)	O.P.+ 2,912 mm (50 mm decrease since 7:00 on April 27)	O.P.+ 2,755 mm (13 mm increase since 7:00 on April 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,410 mm (Increase from initial level:5,627 mm, 5 mm increase since 7:00 on April 27) O.P.+ 2,253 mm (Increase from initial level:2,979 mm, 267 mm increase since 7:00 on April 27) O.P.+ 4,458 mm (Water level from floor:662 mm, 1 mm increase since 7:00 on April 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:13 on April 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:28 on April 27)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed (From 10:00 on April 27 to 15:03 on April 27)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:28 on April 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.