

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 29)**

Water Level of the accumulated water (at 7:00 on April 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,950 mm (6 mm increase since 7:00 on April 28)	O.P.+ 1,773 mm (2 mm decrease since 7:00 on April 28)	—
	Water level of Turbine Building	O.P.+ 2,513 mm (84 mm increase since 7:00 on April 28)	O.P.+ 2,632 mm (7 mm decrease since 7:00 on April 28)	O.P.+ 2,813 mm (52 mm decrease since 7:00 on April 28)	O.P.+ 2,786 mm (4 mm increase since 7:00 on April 28)
	Water level of Reactor Building	O.P.+ 4,585 mm (5 mm decrease since 7:00 on April 28)	O.P.+ 2,740 mm (6 mm decrease since 7:00 on April 28)	O.P.+ 2,851 mm (61 mm decrease since 7:00 on April 28)	O.P.+ 2,768 mm (13 mm increase since 7:00 on April 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,417 mm (Increase from initial level:5,634 mm, 7 mm increase since 7:00 on April 28) O.P.+ 2,804 mm (Increase from initial level:3,530 mm, 551 mm increase since 7:00 on April 28) O.P.+ 4,460 mm (Water level from floor:664 mm, 2 mm increase since 7:00 on April 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:13 on April 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:28 on April 27)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on April 28 to 15:00 on April 28)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24    Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:28 on April 23    In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.