

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 30)

Water Level of the accumulated water (at 7:00 on April 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,955 mm (5 mm increase since 7:00 on April 29)	O.P.+ 1,770 mm (3 mm decrease since 7:00 on April 29)	—
	Water level of Turbine Building	O.P.+ 2,528 mm (15 mm increase since 7:00 on April 29)	O.P.+ 2,705 mm (73 mm increase since 7:00 on April 29)	O.P.+ 2,840 mm (27 mm increase since 7:00 on April 29)	O.P.+ 2,786 mm (No change since 7:00 on April 29)
	Water level of Reactor Building	O.P.+ 4,583 mm (2 mm decrease since 7:00 on April 29)	O.P.+ 2,779 mm (39 mm increase since 7:00 on April 29)	O.P.+ 2,875 mm (24 mm increase since 7:00 on April 29)	O.P.+ 2,773 mm (5 mm increase since 7:00 on April 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,419 mm (Increase from initial level:5,636 mm, 2 mm increase since 7:00 on April 29) O.P.+ 2,604 mm (Increase from initial level:3,330 mm, 200 mm decrease since 7:00 on April 29) O.P.+ 4,462 mm (Water level from floor:666 mm, 2 mm increase since 7:00 on April 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:13 on April 27 to 9:55 on April 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:28 on April 27 to 10:11 on April 29)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:31 on April 30 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.