

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 1)**

Water Level of the accumulated water (at 7:00 on May 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,960 mm (5 mm increase since 7:00 on April 30)	O.P.+ 1,769 mm (1 mm decrease since 7:00 on April 30)	—
	Water level of Turbine Building	O.P.+ 2,529 mm (1 mm increase since 7:00 on April 30)	O.P.+ 2,780 mm (75 mm increase since 7:00 on April 30)	O.P.+ 2,862 mm (22 mm increase since 7:00 on April 30)	O.P.+ 2,798 mm (12 mm increase since 7:00 on April 30)
	Water level of Reactor Building	O.P.+ 4,584 mm (1 mm increase since 7:00 on April 30)	O.P.+ 2,851 mm (72 mm increase since 7:00 on April 30)	O.P.+ 2,900 mm (25 mm increase since 7:00 on April 30)	O.P.+ 2,782 mm (9 mm increase since 7:00 on April 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,423 mm (Increase from initial level:5,640 mm, 4 mm increase since 7:00 on April 30) O.P.+ 2,232 mm (Increase from initial level:2,958 mm, 372 mm decrease since 7:00 on April 30) O.P.+ 4,464 mm (Water level from floor:668 mm, 2 mm increase since 7:00 on April 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank			
		Transfer Completed (From 10:00 on April 30 to 15:00 on April 30)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:22 on April 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:31 AM on April 30, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a absorbance tower replacement. At 4:56 PM on the same day, the apparatus was restarted after the absorbance tower replacement, and the steady flow rate was achieved at 5:22 PM.				

※ For quick publication of the data of water level, values are provided as reference values.