

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 2)**

Water Level of the accumulated water (at 7:00 on May 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,965 mm (5 mm increase since 7:00 on May 1)	O.P.+ 1,767 mm (2 mm decrease since 7:00 on May 1)	—
	Water level of Turbine Building	O.P.+ 2,337 mm (192 mm decrease since 7:00 on May 1)	O.P.+ 2,784 mm (4 mm increase since 7:00 on May 1)	O.P.+ 2,827 mm (35 mm decrease since 7:00 on May 1)	O.P.+ 2,802 mm (4 mm increase since 7:00 on May 1)
	Water level of Reactor Building	O.P.+ 4,595 mm (11 mm increase since 7:00 on May 1)	O.P.+ 2,883 mm (32 mm increase since 7:00 on May 1)	O.P.+ 2,868 mm (32 mm decrease since 7:00 on May 1)	O.P.+ 2,789 mm (7 mm increase since 7:00 on May 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,425 mm (Increase from initial level:5,642 mm, 2 mm increase since 7:00 on May 1) O.P.+ 2,425 mm (Increase from initial level:3,151 mm, 193 mm increase since 7:00 on May 1) O.P.+ 4,464 mm (Water level from floor:668 mm, No change since 7:00 on May 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (From 6:12 on May 1 to 12:20 on May 1)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:35 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:35 on May 1)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:22 on April 30   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.